

Declaration of Performance



N° PL – DoP – GACV / FACV – 2026 – 04

Identification of the product-type : F1522 – 300 / GACV
 Size : 3"/DN 80 Size: 4"/DN 100 Size: 6"/DN 150 Size: 8"/DN 200

Intended use : Wet Alarm Check Valve for Fixed Firefighting Systems

Manufacturer : Piping Logistics BV

Authorised representative : Piping Logistics BV

System of AVPC : System 1

Harmonised standard : EN 12259-2 2005-10-19 +A2: 2006-04-28

Notified Body : 0843 – CPR - 0852
 NoBo N° 0843 + UL International

Declared performance :

Model	Size, mm	Rated Pressure, bar	Notes
Wet Alarm valve assembly			
GACV,FACV	DN80, DN100, DN150, DN200	16	-

Appropriate Technical Documentation : Technical Datasheet FACV & GACV (by Piping Logistics)

The performance of the product(s) identified above is in conformity with the set of declared performances. This Declaration of Performance is issued, in accordance with Regulation (EU) N° 305/201, under the sole responsibility of the representative identified above.

Signed for and on behalf of the manufacturer by :

Name : Thomas Helin
 At : Erembodegem-BELGIUM
 Date : 26/01/2026
 Signature :





EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon, Wade Rd, Basingstoke RG24 8AH, United Kingdom

Certificate of constancy of performance 0843-CPR-0852

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Model GACV and FACV Alarm Valves

Alarm valves for use in fixed firefighting systems

placed on the market under the name or trade mark of

Piping Logistics bv
Industrielaan 27,
9320, Erembodegem,
Belgium

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 12259-2 2005-10-19 +A2: 2006-04-28

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2020/09/28 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

28th September 2020

Mr. Chris Johnson
Staff Engineer

UL International (UK) Limited
Kingsland Business Park, Unit 1-3 Horizon, Wade Rd,
Basingstoke RG24 8AH, United Kingdom
27.CP.00855 Issue: 3.1



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon, Wade Rd, Basingstoke RG24 8AH, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0852

Model	Size, mm	Rated Pressure, bar	Notes
Wet-Alarm valve assembly			
GACV, FACV	DN80, DN100, DN150, DN200	16	—

Product/Device description:

GACV and FACV Alarm Valves for use in fixed firefighting systems

Applicant designation:

Piping Logistics bv
Industrielaan 27,
9320, Erembodegem,
Belgium

Product Information

Investigation of GACV and FACV Alarm Valves.

The referenced product complies with:

A – All the relevant requirements as per EN 12259-2 2005-10-19 +A2: 2006-04-28

28th September 2020

Mr. Chris Johnson
Staff Engineer