

Declaration of Performance



N° PL – DoP – Proflex Braided – 2026 – 05

Identification of the product-type : PF700BH, PF1000BH, PF1200BH, PF1500BH & PF1800BH (Straight Outlet) Braided Flexible Sprinkler Hose

Intended use : Connection of sprinklers in a commercial suspended ceiling in a land-based building or structure to rigid pipework within a wet or dry automatic sprinkler system

Manufacturing Plant : Factory Location 'A'

Authorised representative : Piping Logistics BV

System of AVPC : System 1

Harmonised standard : ETA-24/0405, issued on 21 February 2025 & EAD 100012-00-1106 dated April 2020

Notified Body : 2809 – CPR – F0084
NoBo 2809 + FM Approvals Europe Limited

Declared performance : The product complies with all relevant requirements as per ETA-24/0405, issued on 21 February 2025 and EAD 100012-00-1106 dated April 2020

Appropriate Technical Documentation : Technical Datasheet Proflex (by Piping Logistics)

The performance of the product(s) identified above is in conformity with the set of declared performances. This Declaration of Performance is issued, in accordance with Regulation (EU) N° 305/201, under the sole responsibility of the representative identified above.

Signed for and on behalf of the manufacturer by :

Name : Thomas Helin
At : Industrielaan 27 - 9320 Erembodegem-BELGIUM
Date : 26/01/2026
Signature :

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2809-CPR-F0084

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Piping Logistics BV Models PF700BH, PF1000BH, PF1200BH, PF1500BH & PF1800BH (Straight Outlet) Braided Flexible Sprinkler Hoses

Connection of sprinklers in a commercial suspended ceiling in a land-based building or structure to rigid pipework within a wet or dry automatic sprinkler system

placed on the market under the name or trade mark of

Piping Logistics BV
Industrielaan, 27,
Erembodgem 9320,
Belgium

and produced in the manufacturing plant

Factory Location 'A'

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA-24/0405, issued on 21 February 2025

And

EAD 100012-00-1106 dated April 2020

under system 1 for the performances set out in the ETA 24/0405 are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 21 February 2025 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Richard
Zammitt
FM Approvals
Dublin, Ireland
2024.4.1

Richard Zammitt, Certification Manager
On behalf of FM Approvals Europe Limited
(PR468264 & PR464802)

Issue 1, Dublin, dated 21 February 2025

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin, Ireland D02 E440
E-mail: cpr@fmapprovals.com Web: www.fmapprovals.com

F-CPR-030 (Dec/2020)

This certificate remains the property of FM Approvals and has been issued in accordance with FM Approvals CPR Certification Scheme.

