

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20211123-EX16234  
**Report Reference** EX15192  
**Issue Date** 2021-NOVEMBER-23

**Issued to:** Piping Logistics BV  
Industrielaan 27  
Aalst, 9320 Belgium

**This is to certify that  
representative samples of**

## **Flexible Sprinkler Hose With Fittings**

See addendum page for model information

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 2443 "Flexible Sprinkler Hose with Fittings for Fire  
Protection Service"

**Additional Information:**

See the UL Online Certifications Directory at <https://www.ul.com/certifications> for additional  
information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



# CERTIFICATE OF COMPLIANCE

Certificate Number 20211123-EX16234  
Report Reference EX15192  
Issue Date 2021-NOVEMBER-23

Model	Rated Pressure, psig	Max Ambient Temp, °F	Nom Inlet by Outlet Size, in.	Assembly Length, ft (mm)	Max No. of 90° Bends	Min Bend Radius, in.	Equivalent Length of 1 in. Schedule 40 Steel Pipe (C = 120), ft	Flexibility Type
PF700BH braided	200	150	1x1/2	2.3 (700)	2	5	33	Limited
PF1000BH braided	200	150	1x1/2	3.3 (1000)	3	5	65	Limited
PF1200BH braided	200	150	1x1/2	3.9 (1200)	3	5	67	Limited
PF1500BH braided	200	150	1x1/2	4.9 (1500)	3	5	84	Limited
PF1800BH braided	200	150	1x1/2	5.9 (1800)	3	5	101	Limited
PF700BH braided	200	150	1x3/4	2.3 (700)	2	5	36	Limited
PF1000BH braided	200	150	1x3/4	3.3 (1000)	3	5	59	Limited
PF1200BH braided	200	150	1x3/4	3.9 (1200)	3	5	73	Limited
PF1500BH braided	200	150	1x3/4	4.9 (1500)	3	5	77	Limited
PF1800BH braided	200	150	1x3/4	5.9 (1800)	3	5	105	Limited
PF700UH unbraided	200	150	1x1/2	2.3 (700)	2	5	33	Limited
PF1000UH unbraided	200	150	1x1/2	3.3 (1000)	3	5	65	Limited
PF1200UH unbraided	200	150	1x1/2	3.9 (1200)	3	5	67	Limited
PF1500UH unbraided	200	150	1x1/2	4.9 (1500)	3	5	84	Limited
PF1800UH unbraided	200	150	1x1/2	5.9 (1800)	3	5	101	Limited
PF700UH unbraided	200	150	1x3/4	2.3 (700)	2	5	36	Limited
PF1000UH unbraided	200	150	1x3/4	3.3 (1000)	3	5	59	Limited
PF1200UH unbraided	200	150	1x3/4	3.9 (1200)	3	5	73	Limited

*B. Mahlenz*

Bruce Mahlenz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20211123-EX16234  
**Report Reference** EX15192  
**Issue Date** 2021-NOVEMBER-23

PF1500UH unbraided	200	150	1x3/4	4.9 (1500)	3	5	77	Limited
PF1800UH unbraided	200	150	1x3/4	5.9 (1800)	3	5	105	Limited

All models of flexible sprinkler hose with fittings are intended to be installed with the L-Bracket and S-Bracket in accordance with the manufacturer's installation instructions dated October 29, 2019.

Marking: Tradename or Trademark  
 "PT"

**Profit**

**PROFIT**

, "Profit",

**PT**

,

**PT**

,

*B. Mahlenz*

Bruce Mahrenholz, Director North American Certification Program  
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations>.

