

Certificate of Compliance

Certificate Number:

EX29299

Report Reference:

2024-04-02-EX29299

Issue Date:

2024-APR-10

Issued to:

**PIPING LOGISTICS BV
INDUSTRIELAAN 27
AALST, 9320 BELGIUM |**

This certificate confirms that representative samples of:

Strainers, Pipeline
See addendum for model information

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

UL Subject 321 – Outline of Investigation for Pipeline Strainers

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Owner



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

Certificate of Compliance

Certificate Number: EX29299
Report Reference: EX29299-20240402
Issue Date: 2024-APR-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	End-configuration	Size, NPS	Rated Pressure, psi (kPa)	Approximate Loss of Head at 15 ft/sec (4.6 m/sec) flow velocity
FYST-232	Flange by Flange	2 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	2.5 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	3 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	4 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	5 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	6 in.	232 (1600)	Less than 3 psi (21 kPa)
	Flange by Flange	8 in.	232 (1600)	Less than 3 psi (21 kPa)
	FYST-300	Flange by Flange	2 in.	300 (2068)
Flange by Flange		2.5 in.	300 (2068)	Less than 3 psi (21 kPa)
Flange by Flange		3 in.	300 (2068)	Less than 3 psi (21 kPa)
Flange by Flange		4 in.	300 (2068)	Less than 3 psi (21 kPa)
Flange by Flange		5 in.	300 (2068)	Less than 3 psi (21 kPa)
Flange by Flange		6 in.	300 (2068)	Less than 3 psi (21 kPa)
Flange by Flange		8 in.	300 (2068)	Less than 3 psi (21 kPa)
GYST-362		Groove by Groove	2 in.	365 (2517)
	Groove by Groove	2.5 in.	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	76.1 mm	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	3 in.	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	4 in.	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	139.7 mm	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	5 in.	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	165.1 mm	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	6 in.	365 (2517)	Less than 3 psi (21 kPa)
	Groove by Groove	8 in.	365 (2517)	Less than 3 psi (21 kPa)

