

Certifications



Specifications (UL/FM)

Service Pressure: 450psi.

Flow Sensitivity Range for Signal: 15-37.8L/min (4-10GPM).

Contact Ratings: 8A at 125/250VAC; 3A at 24VDC; 2.5A at 30VDC.

Operating Temperature Range: 0°C up to 49°C.

Compatible pipe: steel pipe, schedule 10 ~ 40 .

Maximum Surge: 5.5 m/s (18FPS).

Specifications (CE)

Service Pressure: 16bar

Flow Sensitivity Range for Signal: 30-57L/min.

Contact Ratings: 8A at 125/250VAC; 3A at 24VDC.

Operating Temperature Range: 0°C up to 68°C.

Compatible pipe: steel pipe, schedule 10 ~ 40.

Maximum Surge: 5.5 m/s (18FPS).

UL/ULC Listed, FM Approved, and CE Certification.



CAUTION

VANE-TYPE WATER FLOW DETECTORS THAT ARE MONITORING WET PIPE SYSTEMS SHALL NOT BE USED IN DRY PIPE, DELUGE, OR PRE-ACTION SYSTEMS. THE SURGES OF WATER IN SUCH SYSTEMS MAY BREAK THE VANE OR DAMAGE THE MECHANISM. DO NOT USE IN POTENTIALLY EXPLOSIVE ATMOSPHERES.

General description

Water flow detectors are mounted to water-filled pipes in sprinkler systems. It is used on steel pipe, schedules 10 through 40, sizes 50mm thru 200mm (2" thru 8"). See Table 1 for detectors sizes.

Water flow in the pipe deflects a vane, which triggers a switch after a specified delay period. All water flow detectors have a pneumatically controlled mechanical delay mechanism. Delays reset if the flow of water stops before the entire delay has elapsed. All switches are actuated when the water flow rate is 10 gallons per minute or greater. This installation manual covers the following water flow detectors for sprinkler.

Table 1 Detectors sizes

Nominal Pipe Size		Model	Max. Pressure Rating (psig)
DN50	2"	WFS	450
DN65	2.5"	WFS	450
DN80	3"	WFS	450
DN100	4"	WFS	450
DN125	5"	WFS	450
DN150	6"	WFS	450
DN200	8"	WFS	450

Installation guidelines

NOTE: Do not leave cover off for an extended period of time.

1. These devices may be mounted on horizontal or vertical pipe. On horizontal pipe they shall be installed on the top side of the pipe where they will be accessible. Be sure there is adequate clearance for installation and removal. See Fig.1 for mounting dimensions.
2. The device should not be installed within 15cm of a fitting which change the direction of the water flow or within 60cm of a valve or drain.
3. Drain the system and drill a hole in the pipe. And be sure the hole is perpendicular to the center of the pipe, as show in Fig.2. If the hole is off center, the vane will bind against the inside wall of the pipe. Use a hole saw in a slow speed drill to cut a hole of the proper diameter, as show in Table 2.
4. Remove burrs and sharp edges from the hole. Clean and remove all scale and foreign matter from the inside of the pipe for a distance equal to the pipe diameter on either side of the hole. Clean the outside of the pipe to remove dirt, metal chips, and cutting lubricant.
5. Roll the vane so that it may be inserted into the hole; do not bend or crease it. Seat the gasket against the saddle and mount the detector into the pipe. Insert the vane so that the arrow on the saddle points in the direction of the water flow. The bushing should fit inside the hole in the pipe.
6. Install the U-bolt and tighten nuts alternately to ensure a uniform seal (see Table 2 for torque values).

Fig.1 Mounting dimensions





Fig.2 Mounting hole location



7. The vane must not rub the inside of the pipe or bind in any way. If the vane binds, remove the detector and correct the cause before proceeding.
8. Ensure that the direction of arrow on the saddle point should be consistent with the direction of the water flow. See Fig.3.

Notes: Remove burrs from edge of hole. Clean out scale and foreign matter from inside wall of pipe.

Table 2 Main dimensions

Nominal Pipe Size		Nominal Pipe Size OD.		Pipe wall thickness				L	H	Hole cut size	U-bolt Nuts torque
				Schedule10		Schedule40					
mm	in	mm	in	mm	in	mm	in	mm	mm	32+1	40-50
DN50	2	60.3	2.375	2.77	0.109	3.91	0.154	84	188		
DN65	2.5	73.0/76.1	2.875	3.05	0.12	5.16	0.203	92	200	51+1	70-95
DN80	3	88.9	3.500	3.05	0.12	5.49	0.216	104	220		
DN100	4	114.3	4.500	3.05	1.12	6.02	0.237	133	245		
DN125	5	139.7/141.3	5.563	3.40	0.134	6.55	0.258	160	272		
DN150	6	168.3	6.625	3.40	0.134	7.11	0.280	187	298		
DN200	8	219.1	8.625	3.76	0.148	8.18	0.322	240	350		

(This torque is only for normal use. The type test torque is recommended to be appropriately increased).

Fig.3 Assembly diagram





Fig.4 Typical electrical connections



Retard Adjustment

The delay can be adjusted by rotating the retard adjustment knob from 0 to max setting. To adjust the setting, turn the adjustment knob clockwise to increase the delay, counterclockwise to decrease it. The time delay should be set at the minimum required to prevent false alarms.

Maintenance

Inspect detectors monthly. If leak are found, replace the detector.



Fig.5 Ground screw

